

Certificate of Product Approval

Licensee:

Nexans Turkiye Endustri ve Ticaret A.S. (Denizli)

Bozburun Mahallesi

Ahmet Nuri Erikoglu Caddesi No.2, Denizli, 20100, Turkey

Factory:

Bozburun Mahallesi

Ahmet Nuri Erikoglu Caddesi No.2, Denizli, 20100, Turkey

Standard:

BS 7846:2015

Description:

Armoured fire resistant power cables

Details:

Resistance to Fire Category F2. The above cables conform to BS 7846 and, by reference, conform to the appropriate requirements of: BS EN 60228, BS EN 60332-1-2, BS EN 60332-3-24, BS EN 61034-2, BS EN 60754-1 and BS 6387 C,W & Z specifications with a 2A fuse, cables of diameter not exceeding 20 mm; cables of diameter exceeding 20 mm subjected to the additional requirements of BS 7846:2015 Annex I.

Materials:

Insulation GP 8, Sheath LTS 1

Brand Name:

N/A

Origin Marks

NEXANS i or NEXANS i) (

Permissible Approvals Marks

BASEC

BASEC name



BASEC roundel

Signed for and on behalf of BASEC Group Ltd

Date: 01/08/2025

Date of original issue: 28/11/2007

Check BASEC website to verify validity.

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No. 13950143, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 6 (11-11-2024) Page 1 of 2



Expiry date:
26/10/2028



Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
4	N/A	Class 2	2	1.5	400
5	N/A	Class 2	3	1.5	400
6	N/A	Class 2	4	1.5	400
7	N/A	Class 2	5	1.5	70
8	N/A	Class 2	7	1.5	4
8	N/A	Class 2	12	1.5	4
8	N/A	Class 2	19	1.5	4
8	N/A	Class 2	27	1.5	4
8	N/A	Class 2	37	1.5	4

Signed for and on behalf of BASEC Group Ltd

Date: 01/08/2025

Date of original issue: 28/11/2007

Check BASEC website to verify validity.

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
 Registered in England No.13950143, Tel: +44 (0)1908 267300
 Email: mail@basec.org.uk Web: www.basec.org.uk

