LPCB®

www.redbooklive.com

Certificate of Product Approval

Certificate Number: 946d

Issue: 04

P R

NEXANS TÜRKIYE ENDÜSTRI VE TICARET A.Ş.

Bozburun Mahallesi Ahmet Nuri Erikoglu Caddesi No: 2 Denizli Turkey

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Product(s)

Cable Types as listed below: NX 600 ALSECURE PLUS

Standard(s) (see Appendix for details)

BS 7846:2015 (Category F2 & F120) EN 60754-2:2014 IEC 60331-21:1999 BS 8519:2010 (Clause 11 Category 3)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Obada Rieea	Obada Piracha	28 January 2022	1 December 2017
Signed for BRE Global Ltd.	Certification Scheme Manager	Date of Issue	Date of First issue
LPCB CERTIFICATION CERTIFICATION CERTIFICATION CERTIFICATION 0007	This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit <u>www.redbooklive.com/terms)</u> . To check the validity of this certificate and appendix please visit <u>www.redbooklive.com/terms</u>). BRE Global Ltd, Garston, Watford, WD25 9XX T: +44 (0)333 321 8811 E: <u>enquiries@breglobal.com</u> LPCB [®] is a registered trademark of the Building Research Establishment Ltd.		

80018

LPCB[®]

Appendix to Certificate No: 946d NEXANS TÜRKIYE ENDÜSTRI VE TICARET A.Ş.

Product name LPCB Ref. No. NX 600 ALSECURE PLUS 946d/01 BS 7846 EN 60754-2 IEC 60331-21 BS 8519 Clause 11 conductor (mm²) See note 2 & 3 See note 3 See note 5 See note 4 4.0 2, 3, 4 & 5 F2 & F120 Complies (90 + 15) minutes Category 3 6.0 2, 3, 4 & 5 F2 & F120 Complies (90 + 15) minutes Category 3 10 2, 3, 4 & 5 F2 & F120 Complies (90 + 15) minutes Category 3 16 2, 3, 4 & 5 F2 & F120 Complies (90 + 15) minutes Category 3 25 2, 3, 4 & 5 F2 & F120 Complies (90 + 15) minutes Category 3 35 2, 3, 4 & 5 F2 & F120 Complies (90 + 15) minutes Category 3 50 2, 3, 4 & 5 F2 & F120 Complies (90 + 15) minutes Category 3 70 2, 3, 4 & 5 F2 & F120 (90 + 15) minutes Complies Category 3 2,3&4 Category 3 95 F2 & F120 Complies (90 + 15) minutes 120 3&4 F2 & F120 Complies (90 + 15) minutes Category 3 150 3 & 4 F2 & F120 Complies (90 + 15) minutes Category 3 3 & 4 Category 3 185 F2 & F120 Complies (90 + 15) minutes

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Obada Neer

 $\langle \circ \rangle$

0007

Ulst		Obada Piracha	28 January 2022	1 December 2017
Signed for BRE Globa	al Ltd.	Certification Scheme Manager	Date of Issue	Date of First issue
LPCB	đ	subject to terms and conditions (for c To check the validity of this certificate		
	UKAS PRODUCT CERTIFICATION	www.redbooklive.com/check, scan th BRE Global Ltd, Garston, Watford, W T: +44 (0)333 321 8811 E: enquiries@	D25 9XX	

LPCB is a registered trademark of the Building Research Establishment Ltd.

 $\langle \diamond \rangle$



© BRE Global Ltd, 2022

80018

Issue: 04

LPCB[®]

Appendix to Certificate No: 946d NEXANS TÜRKIYE ENDÜSTRI VE TICARET A.Ş.

Product name LPCB Ref. No. NX 600 ALSECURE PLUS 946d/01 Nominal csa of BS 7846 FN 60754-2 IEC 60331-21 BS 8519 Clause 11 conductor (mm²) See note 2 & 3 See note 5 See note 3 See note 4 See note 1 240 3 & 4 F2 & F120 Complies (90 + 15) minutes Category 3 300 3 & 4 F2 & F120 Complies (90 + 15) minutes Category 3 3&4 400 F2 & F120 Complies (90 + 15) minutes Category 3

Uo/U 600/1000V

Notes:

1. Stranded conductors only.

0 - ...

0007

- 2. In meeting the requirements of BS 7846:2015 Category F2, the NX 600 ALSECURE PLUS cables met the requirements for smoke density to EN 61034-2:2005+A2:2020, fire resistance to BS 6387:2013 CWZ and achieved less than 0.5% HCI on the insulation, tapes, filler, bedding and outer covering when tested in accordance with EN 60754-1:2014.
- 3. In meeting the requirements of BS 7846:2015 Category F120, the NX 600 ALSECURE PLUS cables listed met the fire resistance
- requirements for 120 minutes to BS 8491:2008 and therefore approve to BS 8519:2010 Category 3 for power cables.
- 4. The NX 600 ALSECURE PLUS cables met the requirements of IEC 60331-21:1999 when tested at a temperature of 950°C for a duration of 90mins + 15mins cool down, at a voltage rating of 600/1000V.
- 5. Tested to general method given in EN 60754-2:2014.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Obada Aleed	Obada Piracha	28 January 2022	1 December 2017
Signed for BRE Global Ltd.	Certification Scheme Manager	Date of Issue	Date of First issue
LPCB	This certificate and appendix remain t subject to terms and conditions (for d To check the validity of this certificate www.redbooklive.com/check, scan th BRE Global Ltd, Garston, Watford, WI T: +44 (0)333 321 8811 E: enquiries@	letails visit <u>www.redbooklive.com/te</u> e and appendix please visit e QR tag or contact us. D25 9XX	

LPCB is a registered trademark of the Building Research Establishment Ltd.





Issue: 04