

Certificate of Product Approval

Licensee:
Nexans Turkiye Endustri ve Ticaret A.S. (Denizli)

Bozburun Mahallesi
Ahmet Nuri Erikoglu Caddesi No.2, Denizli, Turkey

Factory:
Bozburun Mahallesi
Ahmet Nuri Erikoglu Caddesi No.2, Denizli, Turkey

Standard:
BS 8592:2016

Description:
Single core fire resistant cables

Details:
The above cables conform to BS 8592 and, by reference, conform to the appropriate requirements of: BS EN 60228, BS EN 60332-1-2, BS EN 61034-2, BS EN 60754-1 and IEC 60331-3.

Materials:
Insulation EI 5, Sheath NA

Brand Name:
N/A

Origin Mark:
NEXANS i or NEXANS i)

Permissible Approval Marks:

BASEC



BASEC name

BASEC roundel

Signed for and on behalf of the
British Approvals Service for Cables

Tony Lioveri Date: 12/09/2022

Date of original issue: 09/01/2018

Check BASEC website to verify validity.

Page 1 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No. 1150237, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 4 (21-10-2021)



Expiry date:
26/10/2025



Certificate No:
081/001/192
Issue No: 4

Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
2	N/A	Class 2	1	1.5	70

Signed for and on behalf of the
British Approvals Service for Cables

Tony Lioveri Date: 12/09/2022

Date of original issue: 09/01/2018

Check BASEC website to verify validity.
Page 2 of 2



Expiry date:
26/10/2025