

Certificate of Product Approval

Licensee:

Nexans Turkiye Endustri ve Ticaret A.S. (Denizli)

Bozburun Mahallesi

Ahmet Nuri Erikoglu Caddesi No.2, Denizli, Turkey

Factory:

Bozburun Mahallesi

Ahmet Nuri Erikoglu Caddesi No.2, Denizli, Turkey

Standard:

BS 7846:2015

Description:

Armoured fire resistant power cables

Details:

Resistance to Fire Category F120. Tested bend radius 8D. The above cables conform to BS 7846 and, by reference, conform to the appropriate requirements of: BS EN 60228, BS EN 60332-1-2, BS EN 60332-3-24, BS EN 61034-2, BS EN 60754-1, BS 8491 and BS 6387 C,W & Z specifications.

Materials:

Insulation GP 8, Sheath LTS 1

Brand Name:

N/A

Origin Mark:

NEXANS i or NEXANS i)

Permissible Approval Marks:

BASEC

BASEC name



BASEC roundel

Signed for and on behalf of
BASEC Group Ltd

Date: 15/03/2024

Date of original issue: 15/06/2018

Check BASEC website to verify validity.

Page 1 of 2

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No. 13950143, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 5 (20-03-2023)



Expiry date:
26/10/2025



Certificate No:
081/001/197
Issue No: 8

Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
4	N/A	Class 2	2	4	400
5	N/A	Class 2	3	4	400
6	N/A	Class 2	4	4	400
7	N/A	Class 2	5	4	70

Signed for and on behalf of
BASEC Group Ltd

Paul Moly Date: 15/03/2024

Date of original issue: 15/06/2018

Check BASEC website to verify validity.

Page 2 of 2

BASEC Group Ltd, Presley House, Presley Way, Milton Keynes, MK8 0ES, UK
Registered in England No. 13950143, Tel: +44 (0)1908 267300
Email: mail@basec.org.uk Web: www.basec.org.uk

BSF079 Issue 5 (20-03-2023)



Expiry date:
26/10/2025