

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 60142427

Blatt *Sheet*
0001

Ihr Zeichen <i>Client Reference</i>	Unser Zeichen <i>Our Reference</i>	Ausstellungsdatum <i>Date of Issue</i>
	0001--27142104 001	29.08.2019 (day/mo/yr)

Genehmigungsinhaber *License Holder*

NEXANS TURKIYE ENDUSTRI VE TIC. AŞ.
MECIDIYEKÖY MAH. OĞUZ SOKAK NO:4
RÖNESANS BIZ PLAZA KAT: A/1
34387 MECIDIYEKÖY ŞİŞLİ
Türkiye

Fertigungsstätte *Manufacturing Plant*

NEXANS TÜRKİYE ENDÜSTRİ VE TİCARET A.Ş.
MERKEZEFENDİ MAH.
AHMET NURI ERIKOĞLU CAD. NO:2
20020 DENİZLİ
Türkiye

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
EN 50618:2014

Zertifiziertes Produkt (Geräteidentifikation) *Certified Product (Product Identification)*

Lizenzentgelte - Einheit
License Fee - Unit

Cable (Electric Cables for Photovoltaic Systems)

Code designation:	H1Z2Z2-K	26
Cross section:	Between 1,5mm ² to 240mm ² acc. to IEC 60228:2004 Table 3	
Trade mark:	NEXANS	
Rated Voltage:	AC 1/1 kV; DC 1,5 kV Conductor-conductor Conductor-earth	
Ambient temperature:	-40°C to +90°C	
Max. Conductor temp.:	+120°C (for 20.000h)	
Material of insulation:	Halogen free cross-linked compound	
Material of sheath:	Halogen free cross-linked compound	
Color of insulation:	White	
Color of sheath:	Black, red	
Extrusion type:	Co-extrusion	

26

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

